

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Lalaso Krishna Patil.....

(Name of Officers with designation) from THO Office Kadegaon PHED

inspected the Bharati Vidyapeeth English Medium School

(Name & Address of the school) on Kadegaon (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 25/4/2025 dated 29/04/2025

of D.P.H.L. Sangli (PHED Lab) certified that the

Bharati Vidyapeeth English medium school Kadegaon, (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 2026/04/29.

Signature with Seal: [Signature]  
Name: ता.आ.अ.कार्यालय  
Designation: प्रचारित समिती, कडेगाव  
Name & Address of the Office / Department : .....

To Bharati Vidyapeeth English medium school Kadegaon,  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

64 | Page

[Signature]  
Head Mistress  
Bharati Vidyapeeth English  
Medium School, Kadegaon

[Signature]  
Joint Secretary  
Bharati Vidyapeeth, Pune-30.

Maharashtra State public Health Service  
District Public Health Laboratory, Sangli


Email - sanglidphl@gmail.com Phone 0233 2310652


REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

To	✓ Head Mistress, Bharati Vidyapeeth English Medium School, Kadegaon, Tal. Kadegaon, Dist. Sangli.			
With reference to letter No. & Date	33/2025-26	23/04/2025		
Laboratory Reference No.	3/323/13			
Date of Sample Collection	25/04/2025			
Date of Sample Receipt	25/04/2025			
Date of Examination Started	25/04/2025			
Sr. No.	Details of Sample	Examination Results		Remark
		Probable Number of Micro organisms/100ml sample		
		Coliforms	Thermotolerant Coliforms	
1	Water Purifier (RO water), Kadegaon, Tal. Kadegaon, Dist. Sangli.	0	—	Water Sample is potable bacteriologically.
Remark - Nonpotable water can be used for drinking purposes after proper chlorination and with confirmation of sample is retested for bacteriological examination and found potable.				

Report No. 604  
Date 12.9 APR 2025

Receipt No- 7593005  
Amount- 940  
Date- 25 April 2025

  
SCIENTIFIC OFFICER,  
Dist. Public Health Laboratory,  
Sangli

  
Head Mistress  
Bharati Vidyapeeth English  
Medium School, Kadegaon

State / Regional / District / Public Health Laboratory Sangli

E-mail-ID : .....

Phone No. : .....

## REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection : 25/04/25 Date of Receipt : 25/04/25 Date of Examination : 25/04/25

(All the Analytical Results are in mg/Litre except pH, Turbidity)

Sr. No.	TEST PARAMETER	(1)	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
		R.O. water				
1.	Physical Appearance	clear colourless			—	—
2.	Odour	Agreeable			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	0.35			1.0	5.0
4.	pH Value	6.50			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	22.37			250	1000
6.	Nitrates (as NO <sub>3</sub> )	Not detected			45	No relaxation
7.	Total Hardness (as CaCO <sub>3</sub> )	18.80			200	600
8.	Alkalinity (as CaCO <sub>3</sub> )	33.15			200	600
9.	Total Dissolved Solids	76.00			500	2000
10.	Iron (as Fe)	0.06			0.3	No relaxation
11.	Fluoride (as F)	Not detected			1.0	1.5
12.	Other Tests (if any)					
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

SadhavHead Mistress  
Bharati Vidyapeeth English  
Pune-30This report is restricted only for the Sample/s Is Submitted to this Laboratory.  
This Sample/s Is / are not Collected by this Laboratory.Joint Secretary  
Bharati Vidyapeeth, Pune-30.  
[P.T.O.]

REMARKS

A) Sample No. (s) (01) is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

✓ However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

B) Sample No. (s) \_\_\_\_\_ Contains \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

✗ However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

C) Sample No. (s) \_\_\_\_\_ Contains \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

✗ Hence, this / these water Source/s is / are chemically non-potable / unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. 656

Date :- 7 MAY 2025

Forwarded With Compliments To : Head mistress  
Bharati Vidhyapeeth  
English medium school, Kadegaon.  
Tal. Kadegaon.

With reference to letter No. : \_\_\_\_\_ Dated :- 25/04/25

Fees Rs. : 600 + 340 = 940/-

Receipt No. and Date : 7593005  
25/04/25

(Signature)  
**JR. SCIENTIFIC OFFICER,**  
Dist. Public Health Laboratory,  
Sargolli.