

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Lalaso Krishna Patil

(Name of Officers with designation) from THO Office Kadegaon PHED

inspected the Bharti Vidyapeeth English Medium School

(Name & Address of the school) on Kadegaon (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 25/4/2025 dated 29/04/2025

of DPHL Sanqli (PHED Lab) certified that the

Bharti Vidyapeeth English medium school Kadegaon (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 2026/04/29.

**आरोग्य पर्यवेक्षक**

Signature with Seal: ता.आ.अ.कार्यालय

Name पंचायत समिती, कडेगांध

Designation पंचायत समिती, कडेगांध

Name & Address of the Office / Department : .....

To Bharti Vidyapeeth English medium school Kadegaon  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Maharashtra State Public Health Service  
District Public Health Laboratory, Sangli

Email - sanglidphl@gmail.com Phone 0233 2310652

REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

To	✓ Head Mistress, Bharati Vidyapeeth English Medium School, Kadegaon, Tal. Kadegaon, Dist. Sangli.	
With reference to letter No. & Date	33/2025-26	23/04/2025
Laboratory Reference No.	3/323/13	
Date of Sample Collection	25/04/2025	
Date of Sample Receipt	25/04/2025	
Date of Examination Started	25/04/2025	

Sr. No.	Details of Sample	Examination Results		Remark
		Probable Number of Micro organisms/100ml sample		
		Coliforms	Thermotolerant Coliforms	
1	Water Purifier (RO water), Kadegaon, Tal. Kadegaon, Dist. Sangli.	0	—	Water Sample is potable bacteriologically.


Remark - Nonpotable water can be used for drinking purposes after proper chlorination and with confirmation of sample is retested for bacteriological examination and found potable.

Report No. 604  
Date 12.9 APR 2025

Receipt No- 7593005

Amount- 940

Date- 25 April 2025

  
J. R. SCIENTIFIC OFFICER.  
Dist. Public Health Laboratory,  
Sangli.

State / Regional / District / Public Health Laboratory Sangli

E-mail-ID : .....

Phone No. : .....

## REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection : 25/04/25 Date of Receipt : 25/04/25 Date of Examination : 25/04/25

(All the Analytical Results are in mg./Litre except pH, Turbidity)

Sr. No.	TEST PARAMETER	(1)	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
		R.O. water				
1.	Physical Appearance	clear colourless			—	—
2.	Odour	Agreeable			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	0.35			1.0	5.0
4.	pH Value	6.50			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	22.37			250	1000
6.	Nitrates (as NO <sub>3</sub> )	Not detected			45	No relaxation
7.	Total Hardness (as CaCO <sub>3</sub> )	18.80			200	600
8.	Alkalinity (as CaCO <sub>3</sub> )	33.15			200	600
9.	Total Dissolved Solids	76.00			500	2000
10.	Iron (as Fe)	0.06			0.3	No relaxation
11.	Fluoride (as F)	Not detected			1.0	1.5
12.	Other Tests (if any)					
13.						
14.						
15.						
16.						
17.						
18.						
19.						
20.						

• This report is restricted only for the Sample/s is Submitted to this Laboratory.

• This Sample/s is / are not Collected by this Laboratory.